

# Certification Report



Item Number **0560**

Manufacturing date 06.01.2015

Charge No. 01/15

Name

## ANTIFROST 45 (ST)

Application

### Stabiliser acc. EN 934-2:T4

Range of dosage in mass-% of cement 0,5 - 4

---

State liquid  
Steadiness homogeneous  
Colour colorless  
Active substances calcium nitrate

	Target	Tolerance ( $\pm$ )	Measured	Stat. Determin.
Density in g/ml	1,43	0,03	1,449	
Dry substance in mass-%	45	2,3	45,0	
pH-value	4,5 - 6,5		5,6	
Water-soluble chloride content in mass-% max	0,1			0,004
Total value of chlor in mass-% max	0,1			
Alkali content (Na <sub>2</sub> O-equivalent) in mass-% max	1			0,00

---

This document was automatically generated on 12.01.2015 and is valid without signature