

# Certification Report



Item Number **2120**

Manufacturing date **03.03.2015**

Charge No. **01/15**

Name

**ANTIPOR 65 (ST)**

Application

**Stabiliser acc. EN 934-2:T4**

Range of dosage in mass-% of cement **0,2 - 0,4**

---

State liquid  
Steadiness homogeneous  
Colour yellowish  
Active substances oleic acid

	Target	Tolerance ( $\pm$ )	Measured	Stat. Determin.
Density in g/ml	1,04	0,02	1,030	
Dry substance in mass-%	14	1,4	13,8	
pH-value	10 - 12		11,5	
Water-soluble chloride content in mass-% max	0,1			0,006
Total value of chlor in mass-% max	0,1			
Alkali content (Na <sub>2</sub> O-equivalent) in mass-% max	4			1,61

---

This document was automatically generated on 25.03.2015 and is valid without signature