

Certification Report



Item Number **2120**

Manufacturing date **09.12.2014**

Charge No. **17/14**

Name

ANTIPOR 65 (ST)

Application

Stabiliser acc. EN 934-2:T4

Range of dosage in mass-% of cement **0,2 - 0,4**

State **liquid**
Steadiness **homogeneous**
Colour **yellowish**

Active substances **oleic acid**

	Target	Tolerance (\pm)	Measured	Stat. Determin.
Density in g/ml	1,04	0,02	1,029	
Dry substance in mass-%	14	1,4	12,9	
pH-value	10 - 12		11,7	
Water-soluble chloride content in mass-% max	0,1			0,006
Total value of chlor in mass-% max	0,1			
Alkali content (Na ₂ O-equivalent) in mass-% max	4			1,61

This document was automatically generated on 12.01.2015 and is valid without signature