

Certification Report



Item Number **2120**

Manufacturing date 01.09.2015

Charge No. 10/15

Name

ANTIPOR 65 (ST)

Application

Stabiliser acc. EN 934-2:T4

Range of dosage in mass-% of cement 0,2 - 0,4

State liquid
Steadiness homogeneous
Colour yellowish
Active substances oleic acid

	Target	Tolerance (\pm)	Measured	Stat. Determ.
Density in g/ml	1,04	0,02	1,030	
Dry substance in mass-%	14	1,4	14,1	
pH-value	10 - 12		11,4	
Water-soluble chloride content in mass-% max	0,1			0,006
Total value of chlor in mass-% max	0,1			
Alkali content (Na ₂ O-equivalent) in mass-% max	4			1,60

This document was automatically generated on 30.09.2015 and is valid without signature