

Certification Report



Item Number **0206**

Manufacturing date 30.06.2015

Charge No. 03/15

Name

PANTAPOR 66 (LP)

Application

Air entraining agent acc. EN 934-2:T5

Range of dosage in mass-% of cement 0,05 - 0,8

State liquid
Steadiness homogeneous
Colour light blue

Active substances surfactants

| | Target | Tolerance (±) | Measured | Stat. Determ. |
|---|------------|---------------|----------|---------------|
| Density in g/ml | 1 | 0,02 | 1,006 | |
| Dry substance in mass-% | 3,2 | 0,3 | 3,4 | |
| pH-value | 9,5 - 11,5 | | 10,4 | |
| Water-soluble chloride content in mass-% max | 0,1 | | | |
| Total value of chlor in mass-% max | 0,1 | | | |
| Alkali content (Na ₂ O-equivalent) in mass-% max | 1 | | | |

This document was automatically generated on 06.07.2015 and is valid without signature