

Certification Report



Item Number **0206**

Manufacturing date **02.11.2015**

Charge No. **13/15**

Name

PANTAPOR 66 (LP)

Application

Air entraining agent acc. EN 934-2:T5

Range of dosage in mass-% of cement **0,05 - 0,8**

State liquid
Steadiness homogeneous
Colour light blue

Active substances surfactants

	Target	Tolerance (\pm)	Measured	Stat. Determ.
Density in g/ml	1	0,02	1,004	
Dry substance in mass-%	3,2	0,3	3,2	
pH-value	9,5 - 11,5		10,2	
Water-soluble chloride content in mass-% max	0,1		0,007	0,008
Total value of chlor in mass-% max	0,1			
Alkali content (Na ₂ O-equivalent) in mass-% max	1		0,44	0,44

This document was automatically generated on 01.12.2015 and is valid without signature