

# Certification Report



Item Number **2120**

Manufacturing date 02.02.2016

Charge No. 01/16

Name

## ANTIPOR 65 (ST)

Application

### Stabiliser acc. EN 934-2:T4

Range of dosage in mass-% of cement 0,2 - 0,4

---

State liquid  
Steadiness homogeneous  
Colour yellowish  
Active substances oleic acid

	Target	Tolerance (±)	Measured	Stat. Determ.
Density in g/ml	1,04	0,02	1,028	
Dry substance in mass-%	14	1,4	14,0	
pH-value	10 - 12		11,4	
Water-soluble chloride content in mass-% max	0,1			0,007
Total value of chlor in mass-% max	0,1			
Alkali content (Na <sub>2</sub> O-equivalent) in mass-% max	4			1,59

---

This document was automatically generated on 09.03.2016 and is valid without signature