

# Certification Report



Item Number **2063**

Manufacturing date **22.08.2016**

Charge No. **13/16**

Name

**ANTIPOR 63 (BV)**

Application

**Concrete plasticizer for concrete acc. EN 934-2:T2**

Range of dosage in mass-% of cement **0,2 - 2,15**

State liquid  
Steadiness homogeneous  
Colour amber

Active substances modified polycarboxylates

	Target	Tolerance ( $\pm$ )	Measured	Stat. Determ.
Density in g/ml	1,02	0,02	1,020	
Dry substance in mass-%	9,5	0,95	9,7	
pH-value	4,5 - 6,5		5,5	
Water-soluble chloride content in mass-% max	0,1			0,008
Total value of chlor in mass-% max	0,1			
Alkali content (Na <sub>2</sub> O-equivalent) in mass-% max	4			0,19

This document was automatically generated on 30.08.2016 and is valid without signature