

Certification Report



Item Number **0206**

Manufacturing date **04.03.2016**

Charge No. **01/16**

Name

PANTAPOR 66 (LP)

Application

Air entraining agent acc. EN 934-2:T5

Range of dosage in mass-% of cement **0,05 - 0,8**

State liquid
Steadiness homogeneous
Colour light blue

Active substances surfactants

| | Target | Tolerance (\pm) | Measured | Stat. Determin. |
|---|------------|---------------------|----------|-----------------|
| Density in g/ml | 1 | 0,02 | 1,005 | |
| Dry substance in mass-% | 3,2 | 0,3 | 3,3 | |
| pH-value | 9,5 - 11,5 | | 10,8 | |
| Water-soluble chloride content in mass-% max | 0,1 | | | 0,008 |
| Total value of chlor in mass-% max | 0,1 | | | |
| Alkali content (Na ₂ O-equivalent) in mass-% max | 1 | | | 0,44 |

This document was automatically generated on 09.03.2016 and is valid without signature