

Certification Report



Item Number **0220**

Manufacturing date **08.07.2016**

Charge No. **09/16**

Name

PANTAPOR 2000 (LP)

Application

Air entraining agent acc. EN 934-2:T5

Range of dosage in mass-% of cement **0,05 - 0,8**

State liquid
Steadiness homogeneous
Colour brown
Active substances modified root resin

	Target	Tolerance (\pm)	Measured	Stat. Determ.
Density in g/ml	1	0,02	1,004	
Dry substance in mass-%	2,1	0,2	2,1	
pH-value	11 - 13		12,0	
Water-soluble chloride content in mass-% max	0,1			0,008
Total value of chlor in mass-% max	0,1			
Alkali content (Na ₂ O-equivalent) in mass-% max	1			0,40

This document was automatically generated on 25.07.2016 and is valid without signature