

# Certification Report



Item Number **0104**

Manufacturing date 10.05.2016

Charge No. 07/16

Name

## PANTARHIT 15 (BV)

Application

### Concrete plasticizer for concrete acc. EN 934-2:T2

Range of dosage in mass-% of cement 0,2 - 1

---

State liquid  
Steadiness homogeneous  
Colour brown  
Active substances ligninsulfonates

	Target	Tolerance ( $\pm$ )	Measured	Stat. Determ.
Density in g/ml	1,14	0,03	1,133	
Dry substance in mass-%	26	1,3	25,5	
pH-value	4 - 6		5,4	
Water-soluble chloride content in mass-% max	0,1			0,020
Total value of chlor in mass-% max	0,1			
Alkali content (Na <sub>2</sub> O-equivalent) in mass-% max	1			0,09

---

This document was automatically generated on 16.08.2016 and is valid without signature