

Certification Report



Item Number **2920**

Manufacturing date 14.03.2017

Charge No. 01/17

Name

PROTECT NTP

Application

concrete protection

Range of dosage in mass-% of cement -

State	liquid
Steadiness	homogeneous
Colour	white
Active substances	acryl styrene polymer

	Target	Measured	Stat. Determ.
Density in g/ml	1,00 - 1,04	1,019	
Dry substance in mass-%	28,5 - 31,5	29,2	
pH-value	7,5 - 9,5	8,1	

This document was automatically generated on 12.07.2017 and is valid without signature