

Certification Report



Item Number **0206**

Manufacturing date 20.10.2014

Charge No. 03/14

Name

PANTAPOR 66 (LP)

Application

Air entraining agent acc. EN 934-2:T5

Range of dosage in mass-% of cement 0,05 - 0,8

State liquid
Steadiness homogeneous
Colour light blue

Active substances surfactants

	Target	Tolerance (\pm)	Measured	Stat. Determin.
Density in g/ml	1	0,02	1,004	
Dry substance in mass-%	3,2	0,3	3,2	
pH-value	10,5 - 12,5		10,6	
Water-soluble chloride content in mass-% max	0,1			0,008
Total value of chlor in mass-% max	0,1			
Alkali content (Na ₂ O-equivalent) in mass-% max	1			0,41

This document was automatically generated on 23.10.2014 and is valid without signature