

# Certification Report

Item Number **0101**

Manufacturing date 26.03.2014

Charge No. 10/14

Name

**PANTARHIT 35 (BV)**

Application

**Concrete plasticizer for concrete acc. EN 934-2:T2**

Range of dosage in mass-% of cement 0,2 - 0,9

---

State liquid

Steadiness homogeneous

Colour brown

Active substances lignin sulphonate

	Target	Tolerance ( $\pm$ )	Measured	Stat. Determ.
Density in g/ml	1,21	0,03	1,218	
Dry substance in mass-%	40	2	39,1	
pH-value	4 - 6		4,8	
Water-soluble chloride content in mass-% max	0,1			0,022
Total value of chlor in mass-% max	0,1			
Alkali content (Na <sub>2</sub> O-equivalent) in mass-% max	1			0,14

---

This document was automatically generated on 28.04.2014 and is valid without signature