

Certification Report



Item Number **0220**

Manufacturing date **29.04.2014**

Charge No. **07/14**

Name

PANTAPOR 2000 (LP)

Application

Air entraining agent acc. EN 934-2:T5

Range of dosage in mass-% of cement **0,05 - 0,8**

State liquid
Steadiness homogeneous
Colour brown
Active substances modified root resin

	Target	Tolerance (±)	Measured	Stat. Determ.
Density in g/ml	1	0,02	1,007	
Dry substance in mass-%	2,1	0,2	2,1	
pH-value	11 - 13		12,0	
Water-soluble chloride content in mass-% max	0,1			0,007
Total value of chlor in mass-% max	0,1			
Alkali content (Na ₂ O-equivalent) in mass-% max	1			0,40

This document was automatically generated on 15.05.2014 and is valid without signature